



सत्यमेव जयते

GOVT. OF ASSAM  
OFFICE OF THE DIRECTOR  
FIRE & EMERGENCY SERVICES, GUWAHATI  
ASSAM



UBIN : 294/816854/NOPAN/2/2023

UAIN : FIRNOCXII/2023/01850

**ACKNOWLEDGEMENT OF RENEWAL NO OBJECTION CERTIFICATE**

To,

Dr. Ajit Boro  
Nepalpara, Habrubil, Gossaigaon,  
KOKRAJHAR, Pin 783360

Subject to the provisions of the Govt. OM No. HMB.362/2019/68 dated 28.06.2022, Corrigendum No. HMB.362/2019/71 dated 08.07.2022 & Letter No. HMB.362/2019/72 dated 08.07.2022 and Self Declaration received in prescribed form on dated 28/03/2023, renewal of the Fire Safety No Objection Certificate for the purpose of COLLEGE is hereby granted to the building or premises under the name and style Gossaigaon B.Ed. College and as per description below at Dag No. 73, Patta No. , Mouza Gossaigaon, (Place - Gossaigaon, , KOKRAJHAR) for a period of 3 Years from the date of issue unless the No Objection Certificate has not been cancelled or suspended for non-compliance of any of the conditions of the undertaking submitted by the owner or occupier of the building or premises.

**DETAILS OF APPROVED OCCUPATION**

S. No.	Floor	Floor Area	Purpose of Utilization
1.	GROUND FLOOR	7955.25 SQM	COLLEGE

Hazard Category: **Low Hazard**

THIS NOC IS VALID UP TO **29/3/2026**

Place of issue: **GUWAHATI**

Date of issue : **30/03/2023**

Director of Fire and Emergency Services,  
Assam, Guwahati.

**CONDITIONS :**

1. This N.O.C. is not transferable in respect of name, place and purpose of utilization.
2. There should not be any change or alteration of Trade/purpose of utilization for which this N.O.C. has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. It will be compulsory to obtain fresh Fire Safety No Objection Certificate from Assam Fire & Emergency Services prior to any change in occupation or alteration to building or premises.
5. The Fire Fighting equipments should be in serviceable condition at all times.
6. Water reservoir should always be kept full up to brim.
7. The entrance and exit and the water reservoir should always be free from any obstruction/projection.
8. The responsibility to continuously maintain fire prevention and life safety measures provided in the building or premises shall

be of the owner or occupier or association of such owners or occupiers of the building or premises and the fire fighting arrangement should be in workable condition round the clock.

9. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted and would lead to penalty/disconnection of power supply/cancellation of Trade License/sealing the building or premises etc.**

Director of Fire and Emergency Services,  
Assam, Guwahati.



Note : This certificate is computer generated and does not require any Seal/Signature.



# FIRE TESTING CERTIFICATE

**NORTHEAST FIRE SERVICE**

**GUWAHATI, PANBAZAR ASSAM, 781001**

Date... 24-04-2025

REG. NO:- MHGP17002155GP


TO WHOM IT MAY CONCERN

*This is to certify that undernoted portable/moveable Chemical Fire Extinguishers have this day been subjected to hydrolic pressure test of 30 kg. per square cm for two & a half minute with following results.*

Sl No	Type of Extinguisher	Qunty	Date of supply/ refill	Date of expiry	Report
1	Abc fire ext. 9 kg	✓	—	—	—
2	Co2 fire ext 4.5kg/2.5kg	1 Nos	24-04-2025	23-04-2026	ok
3	Abc fire ext. 4 kg/2kg	12 Nos	24-04-2025	23-04-2026	ok
4	Macanical foam 9 ltr				

Name and Address:-

Gosaingaon B.E D College, Gosaingaon.

  
24/4/25

For Northeast fire Service

Northeast Fire Service  
Guwahati- 781001  
Date.....